

**PUBLIC NOTICE-CUSTOMERS OF
JASPER COUNTY PWS 1
FAILURE TO MEET MICROBIOLOGICAL MONITORING
REQUIREMENTS FOR DRINKING WATER**

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Routine samples for total coliform bacteria are required to be collected at regular intervals throughout each month. During **October 2025**, we did not properly collect samples at regular intervals throughout the month for total coliform bacteria. This is a violation of Missouri Public Drinking Water Regulations.

Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did to correct the situation. Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or by distributing copies by hand or mail.

Provide explanation of cause of monitoring failure:

We did not collect samples on two separate days.
We collected all 6 samples on the same day.

For more information, please contact water system staff indicated below:

Cristle Swager at 417-781-8844 or PO Box 787 Carl Junction
(name of water system contact) (phone number) (mailing address) Missouri 64831

Additionally, you may contact the department's Southwest Regional Office at 427-891-4300 or Public Drinking Water Branch at 573-526-6925.

This notice is being sent to you by JASPER COUNTY PWS 1
State Water System ID# MO5024286